

INTERNATIONAL JOURNAL OF ENERGY RESEARCH

Int. J. Energy Res. 2006; **30**:811–822

Published online 9 February 2006 in Wiley InterScience (www.interscience.wiley.com). DOI: 10.1002/er.1187

Short-term load forecast using trend information and process reconstruction

P. J. Santos^{2,‡}, A. G. Martins^{1,*}, A. J. Pires^{2,§}, J. F. Martins^{2,¶} and R. V. Mendes^{3,||}

¹ *Department of Electrical Engineering FCTUC/INESC, Polo 2 University of Coimbra, Pinhal de Marrocos, 3030 Coimbra Portugal*

² *LabSEI-Department of Electrical Engineering, ESTSetúbal/Instituto Politécnico de Setúbal, Rua do Vale de Chaves Estefanilha 2914-508 Setúbal Portugal*

³ *Laboratório de Mecatrónica, Instituto Superior Técnico, Av. Rovisco Pais, 1096 Lisboa Codex, Lisboa Portugal*

SUMMARY

The algorithms for short-term load forecast (STLF), especially within the next-hour horizon, belong to a group of methodologies that aim to render more effective the actions of planning, operating and controlling electric energy systems (EES). In the context of the progressive liberalization of the electricity sector, unbundling of the previous monopolistic structure emphasizes the need for load forecast, particularly at the network level. Methodologies such as artificial neural networks (ANN) have been widely used in next-hour load forecast. Designing an ANN requires the proper choice of input variables, avoiding overfitting and an unnecessarily complex input vector (IV). This may be achieved by trying to reduce the arbitrariness in the choice of endogenous variables. At a first stage, we have applied the mathematical techniques of process-reconstruction to the underlying stochastic process, using coding and block entropies to characterize the measure and memory range. At a second stage, the concept of consumption trend in homologous days of previous weeks has been used. The possibility to include weather-related variables in the IV has also been analysed, the option finally being to establish a model of the non-weather sensitive type. The paper uses a real-life case study. Copyright © 2006 John Wiley & Sons, Ltd.

KEY WORDS: distribution systems; load forecasting; measure; memory range; consumption trend; artificial neural networks

1. INTRODUCTION

Distribution companies (DISCO) operating on a scenario of complete or partial unbundling of the electricity sector are confronted with increasing demands on planning, management and

*Correspondence to: A. G. Martins, Department of Electrical Engineering FCTUC/INESC, Polo 2 University of Coimbra, Pinhal de Marrocos, 3030 Coimbra Portugal.

[‡]E-mail: amartins@deec.uc.pt

[‡]E-mail: psantos@est.ips.pt

[§]E-mail: apires@est.ips.pt

[¶]E-mail: amartins@est.ips.pt

^{||}E-mail: vilela@cii.fc.ul.pt

Received 10 October 2004

Revised 27 October 2005

Accepted 7 November 2005

operation of the networks. Relations with generation, transmission and retail companies (GENCO, TRANSCO, RESCO) are now becoming increasingly complex (Gross and Galiana, 1987). Therefore, DISCOs play a major role in the managing and planning of distribution, with an emphasis on the quality of the supply.

The supply quality rules that are being imposed by the regulatory authorities are becoming more and more demanding. Thus, forecast plays a key role in this sector (Philipson and Willis, 1998). Several short-term load forecast (STLF) models have been developed in the last few decades (Drezga and Rhaman, 1998; Hippert *et al.*, 2001). However, few amongst them have done a specific analysis of this sector (Chen *et al.*, 1996; Fidalgo, 1999; Sargunaraj *et al.*, 1997). Next-hour load forecast allows DISCOs to address issues such as: network reconfiguration, voltage control, maintenance planning and power factor correction. Methodologies for STLF forecast are divided in three major groups (Al-Hamadi and Soliman, 2004): models that are independent of weather changes (non-weather sensitive models), models depending on weather changes (weather-sensitive models), and hybrid models. Methodologies based on artificial neural networks (ANNs) have been widely used with, to some extent, satisfactory results. However, design options are not always fully justified and frequently the models have a high complexity level (Hippert *et al.*, 2001).

The most important type of variable included in the input vector (IV) is the past time-series of the variable being forecast (Hippert *et al.*, 2001; Senjyu *et al.*, 2002; Papalexopoulos *et al.*, 1994; Khotanzad *et al.*, 1997). Other variables, of an auxiliary nature, are used and, not being directly related to electricity consumption, they are usually represented by functions of the sinusoidal or binary type with the goal of helping the ANN to detect periodic features of the load behaviour (Drezga and Rhaman, 1998; Fidalgo, 1999).

The model that was developed, taking into consideration the pre-established time horizon and the low correlation between active load and weather variables may be considered a non-weather sensitive model (Al-Hamadi and Soliman, 2004). In fact, the active power time-series $p(t)$ itself contains the most important IV data.

In order to diminish arbitrariness in the definition of the IV and the prediction algorithm, we have attempted a mathematical characterization of the stochastic process underlying the data in the experimental time-series. Reconstruction of a process involves two different, but related, steps. One is the identification of the *grammar* of the process, that is, the allowed transitions in the state space. The second step is the identification of the *measure*, which concerns the occurrence frequency of each orbit in typical samples. Identification of grammars and measures (in particular Gibbs measures) has been dealt with recently, in particular in the context of hydrodynamic turbulence and market analysis (Chazottes *et al.*, 1998; Mendes *et al.*, 2002). Some of these techniques will be applied in Section 3 to our experimental time-series.

The correlation between active load values in homologous days of the week has also been considered.

The paper has the following structure: the case study is presented in Section 2, where the different types of substations are described, along with the collected data, the time length of the data series and the results of various correlations between consumption and weather variables. The application of the process reconstruction techniques is carried out in Section 3. In Section 4, the concept of trend is used and the IV established. Section 5 presents results from the simulations. Finally, some conclusions on the methodology are included in the last section.

2. DATA ANALYSIS AND CASE STUDY CHARACTERISTICS

The case study is located around the city of Coimbra, in the centre of Portugal, comprising three substations. Installed capacity and voltage level of these substations is of average dimension (Alegria (ALG), Relvinha (RLV) e Alto de São João (ASJ)) (Figure 1). These three substations are responsible for the electrical power supply to the city of Coimbra. The data series obtained from each of these substations have a time span of approximately 3 years (from 21 December 1998 to 20 December 2001).

Data on the following variables was collected: active power (MW), inductive and capacitive reactive power (Mvar), with a maximum time resolution of 1 h. Several types of weather variables were also collected, with the purpose of carrying out correlation analyses, in order to assess the advantages of including these variables in the IV. Correlation of electricity consumption with climatic data may be strong in certain climates, particularly when high humidity and temperature are current in summer or very low temperatures occur in winter. In the case study, moderate temperature swings are accompanied by moderate humidity conditions as well. Hence, a strong correlation was not to be expected (Santos *et al.*, 2003).

Analysing the diagram in Figure 2, one observes that the daily peak load drops with the coming of warmer seasons, which indicates a low impact of ventilation and air conditioning loads. According to this, one would expect stronger correlations only in the wintertime. The




Figure 1. Simplified one-line diagram of the medium voltage network supplying the city of Coimbra.




Figure 2. (a) Scatter plot between the daily peak-load and the maximum temperature; and (b) variation of the peak demand (in both cases between December 1998 and October 2000, city of Coimbra).




Figure 3. Scatter plot of the hourly values of active power load at hour t and temperature at hour $t-2$, 11:00 a.m. to 11:00 p.m., from 21 December 1998 to 15 March 1999.

forecast time spans, as well as the weather conditions, do not favour strong correlations between temperature and electrical energy consumption (Figure 3). Based on this analysis, the composition of the IV relies essentially on the endogenous variables.

3. PROCESS RECONSTRUCTION AND MEMORY RANGE

Usually, the number of consumption instances, prior to the value to be estimated, that one must take into account, is established in an arbitrary manner, based on experience obtained by using correlation analysis (Drezga and Rhaman, 1998; Hippert *et al.*, 2001) (Figure 4). What one must find out is whether the amount of contiguous information that is chosen is appropriate or whether it merely contributes to over-parameterize the model.

Coding and computing block entropies as used in Mendes *et al.* (2002) allows a rigorous estimation of the effective memory range of process. This study was carried out for the data




Figure 4. Daily load pattern—contiguous instances of consumption (active power).

from the three substations yielding similar results. For that reason, it has been decided to present only the results referring to the substation RLV (Figure 1).

The data was collected by the existing supervisory control and data acquisition system (SCADA), with the time-scale resolution of 1 h. The data collection started in 21 December 1998. The period chosen for the analysis of the process was from 21 December 1998 to 15 March 2001, producing a set of $N = 19\,584$ values. The signal was discretized according to the alphabet: $\Sigma = \{-5, -4, -3, -2, -1, 0, 1, 2, 3, 4, 5\}$, containing 11 levels ($k = 11$). This discretization allows a satisfactory representation of the active power load pattern (Figure 5). The whole signal length is, thereby, translated by means of this alphabet and the active power series described by symbol sequences $\omega = p_1, p_2, \dots, p_i, \dots, p_k \in \Sigma$.

In the alphabet Σ the maximal number of distinct blocks of length N is 11^N . The graph of Figure 6(a) compares, for each size N , the actual number of distinct blocks that are present in the signal with the maximum 11^N . The deviation of the values from the maximum shows that the signal rather than being completely random, has a non-trivial grammar.

A very general class of measures for stochastic processes is the class of Gibbs measures. In this context a very simple characterization of the memory range of the process is obtained from the growth of the block entropies. Let

$$H_k = - \sum_{p_1 \dots p_k} \mu[p_1 \dots p_k] \log(\mu[p_1 \dots p_k]) \quad (1)$$

be the entropy associated to blocks of size k , $\mu[p_1 \dots p_k]$ representing the probability of finding within the series a sequence of contiguous values of the $p_1 \dots p_k$ type (Chazottes *et al.*, 1998; Mendes *et al.*, 2002). Using the empirical block probabilities $\mu[p_1 \dots p_k]$ one computes H_k for successively larger k . Then, the memory range of the process is found when $H_k - H_{k-1}$ tends to a constant value. In practice, for a long memory process, this difference after converging to its constant value, starts to decrease. This is an effect of lack of statistics, because for a finite sample there is a small probability that all grammatically allowed blocks will appear in the signal.

The graph of Figure 6(b) shows the $H_k - H_{k-1}$ values computed for our time-series. It clearly shows the short-term memory of the signal, in the sense that the next-hour value depends




Figure 5. Example of the discretization of the original SCADA data by means of the proposed alphabet (RLV substation).




Figure 6. (a) Possible and actual numbers of combinations of blocks of the alphabet; and (b) entropy values.

essentially on the information related to the previous state. Therefore, it may be assumed that the information based on many contiguous values is of small importance and that the main focus should be on incorporating into the IV the information regarding the previous hour together with other (non-time-contiguous) information as explained below.

4. THE TREND CONCEPT

The analysis of block entropies has revealed that the use of long chains of contiguous values does not result in any sort of advantage in the design of the IV of the ANN. Moreover it possibly contributes to an overparameterization of the model.




Figure 7. Auto-correlation values, showing local maxima at homologous instants in the past.




Figure 8. Time-scale divisions adopted in the analyses of active power time-series.

The composition of the IV will have to rely essentially on a careful analysis of both the auto-correlations of the active power and its possible interdependences with the exogenous variables. One notices that the values of auto-correlation are more important in the cases of the two previous hours, deteriorating quite rapidly for deeper excursions into the past. This behaviour is to be expected due to the fact that one is comparing different periods of the day (Figure 7). The values become higher when one considers the correlation of the most recently available active power values with those of homologous instants of homologous days of previous weeks, showing two relative maxima in the two previous weeks (Figure 7).

One should point out the similarity between the coefficients around the homologous values $p(t-168)$ and $p(t-336)$. The inclusion of these values $p(t-167)$, $p(t-169)$, $p(t-335)$ and $p(t-337)$ in the IV provides information regarding the consumption trend in past homologous periods. The evolution of the auto-correlation coefficients is always downward as one moves deeper into the past, which can be explained by the seasonal variation of consumption, which entails different load patterns.

We have, therefore, divided the information into periods (Figure 8), according to the evolution of the average daily temperature.

In spite of the low correlation of electricity consumption with weather variables in this forecast horizon, this division into periods allows for a neural network (ANN) that has been trained in a given period to be used in a simulation in similar weather conditions, helping the network to better deal with weather-related effects. The IV is the one defined in Figure 9. It also includes reactive power instances in the 2 h prior to the forecast $Q(t-1)$ and $Q(t-2)$, due to the fact that they show important correlations with the target variable, and generate improvements

Example of input vector								forecast
day	98/12/21	98/12/22		98/12/28	98/12/29		99/01/04	99/01/05
time	0:00 pm	1:00 am	2:00 am	0:00 pm	1:00 am	2:00 am	11:00 pm	0:00 pm
variable	P(t-337)	P(t-336)	P(t-335)	P(t-169)	P(t-168)	P(t-167)	P(t-2)	P(t-1)
							Qi(t-2)	Qi(t-1)
								P(t)

Figure 9. Composition of the input vector.

Table I. Next hour forecast active power—data analysis.

RLV substation	ME (MW)	MAD (MW)	MSE (MW ²)	RSE (MW)	MPE (%)	MAPE (%)
Period 5 from 99/12/21 to 00/03/15	-0.03	0.36	0.25	0.50	-0.27	2.27
Period 6 from 00/03/16 to 00/05/31	-0.03	0.41	0.41	0.64	-0.43	2.76
Period 7 from 00/06/01 to 00/09/15	0.05	0.28	0.15	0.38	0.42	1.97
Period 8 from 00/09/16 to 00/12/20	-0.02	0.33	0.22	0.47	-0.33	2.16
Period 9 from 00/12/21 to 01/03/15	-0.11	0.37	0.31	0.56	-0.75	2.31
Period 10 from 01/03/16 to 01/05/31	-0.02	0.27	0.16	0.40	-0.31	2.04
Period 11 from 01/06/01 to 01/09/15	0.05	0.26	0.13	0.36	0.42	1.97
Period 12 from 01/09/16 to 01/12/20	-0.11	0.37	0.27	0.52	-1.09	2.75

in the performance of the model (Santos *et al.*, 2003). This is shown through the beneficial influence on the mean squared error (MSE) regarding the ANN training set of values.

5. SIMULATION RESULTS

Standard feedforward backpropagation ANN have been used for the forecast models, with a fully connected architecture and a single hidden layer, the hyperbolic tangent being used as the




Figure 10. Results of simulations, showing a 1 week time span: (a) actual and predicted active power values; and (b) corresponding MPE values.

common activation function. The output is activated with linear functions. The number of neurons in the hidden layer was half of the one of the input layer. The IV was normalized between -1 and 1 . This is a well-proven arrangement, adequate when, as in the present case, the relations between the variables at stake have a strong non-linear behaviour (Hippert *et al.*, 2001).

Simulations have been carried out with data not used in training, testing or validating the ANN. In order to evaluate the performance of the forecast model, some current statistical indicators are used (De Lurgio, 1998). The most significant indicator, as is generally accepted for comparing different approaches, is the mean average percentage error (MAPE) (Hippert *et al.*, 2001). Other statistical indicators are also necessary, in order to provide a more comprehensive view of the forecast results. Parameters such as the mean percentage error (MPE), mean error (ME) should not deviate much from zero, as a sign of a desirable lack of bias in the forecast period. Other statistical indicators are relevant as the mean absolute deviation (MAD), MSE and the residual standard error (RSE). In Table I a set of calculated parameters is presented for the same periods that help to assess the model performance.

Figure 10 shows some examples of the results obtained with the models of the next-hour load forecasts, which should be self-explanatory.

It is difficult to make an exact comparative study with different documented approaches. In fact, there are many factors influencing the design of the ANN which are unknown, such as, for example, the internal structure or the number of training epochs used. However, it is possible to compare the developed IV with a different structure developed by Fidalgo (1999) (Figure 11). This IV was formerly applied to the distribution sector in the north region of Portugal. It uses four contiguous precedent values of the active power $p(t-1)$, $p(t-2)$, $p(t-4)$ and $p(t-4)$ and

Example of input vector developed by Fidalgo							forecast
day	98/12/22	98/12/29	99/01/04				99/01/05
time	1:00 am	1:00 am	9:00 pm	10:00 pm	11:00 pm	0:00 pm	1:00 am
variable	$P(t-336)$	$P(t-168)$	$P(t-4)$	$P(t-3)$	$P(t-2)$	$P(t-1)$	$P(t)$

+ hour code $\sin(2\pi h/24) \cos(2\pi h/24) \quad h = 1, 2, \dots, 24$

+ day code $\sin(2\pi d/24) \cos(2\pi d/24) \quad d = 1, 2, \dots, 7$

Figure 11. Input vector developed by Fidalgo (1999).

Table II. Next hour forecast active power—data analysis between different input vectors.

	ME (MW)	MAD (MW)	MSE (MW ²)	RSE (MW)	MPE (%)	MAPE (%)
Developed vector simulation period from 03/01/05 to 03/01/15	0.12	0.46	0.50	0.64	0.31	1.63
Fidalgo vector simulation period from 03/01/05 to 03/01/15	0.06	0.69	0.88	0.85	0.02	2.53

those of the past 2 weeks $p(t-168)$ and $p(t-336)$. It also uses information of four sinusoidal functions with the aim of informing the ANN of the consumption cycles, according to the hour of the day and the day of the week. A comparative result of the MAPE is presented in Table II.

The MAPE value is better in the case of the developed vector.

6. CONCLUSIONS

STLF has an important role in the electricity distribution sector, as it is subsidiary to the control and management of networks, aiding in decision-making. The growing tendency towards electric systems unbundling makes the implementation of forecast methodologies in all levels of the EES all the more necessary.

The ANN, working as a methodology for short-term forecast, has been widely used with satisfactory results. However, there are always some arbitrary traits in the choice of the variables that constitute the IV. To reduce this arbitrariness, the concepts of memory range (through block entropies estimation) and consumption trend have been used, with the aim of defining IVs of small dimensions, avoiding model overparameterization.

This kind of vector has been compared to other proposals in the literature, showing in general satisfactorily improved results. The models were trained with consumption values of the year 1999 and simulation has been performed up until 2002, maintaining a good performance level throughout. They were also tested in different types of substations with different load configurations. The reactive power was also included in the composition of the IV, producing a slight improvement in the model behaviour.

ACKNOWLEDGEMENTS

The authors gratefully acknowledge the contributions of EDP Distribuição—Direcção do Centro for all the data provided and João T. Martins for his careful translation.

REFERENCES

- Al-Hamadi H, Soliman S. 2004. Short-term load forecasting based on Kalman filtering algorithm with moving window weather and load model. *EPSR—Electric Power Systems Research* **68**:47–59.
- Chazottes J, Floriani E, Lima R. 1998. Relative entropy and identification of Gibbs measures in dynamical systems. *Journal of Statistical Physics* **90**(3/4):697–725.
- Chen C, Tzeng Y, Hawang J. 1996. The application of artificial neural networks to substation load forecasting. *Electric Power Systems Research* **38**:153–160.
- De Lurgio S. 1998. *Forecasting Principles and Applications*. International editions, Statistics and Probability Series. McGraw-Hill: Singapore; 36–58.
- Drezga I, Rhaman S. 1998. Input variable selection for ANN-based short-term load forecasting. *IEEE Transactions on Power Systems* **13**(4):1238–1244.
- Fidalgo J. 1999. Previsão de carga em saídas de Subestações—resultados preliminares *ELAB'994° encontro Luso-Afro-Brasileiro de Planeamento e Exploração de Redes de Energia*; 339–348.
- Gross G, Galiana F. 1987. Short term load forecasting. *IEEE Proceedings* **75**(12):1558–1573.
- Hippert H, Pereira C, Souza R. 2001. Neural networks for short-term load forecasting: a review and evaluation. *IEEE Transactions on Power Systems* **16**(1):44–55.
- Khotanzad A, Afkhami-Rohani R, Tsun-Liang Lu, Abaye A, Davis M, Maratukulam D. 1997. ANNSTLF—A neural network based electric load forecasting system. *IEEE Transactions on Neural Networks* **8**(4):835–845.

- Mendes R, Lima R, Araújo T. 2002. A process-reconstruction analysis of market fluctuations. *International Journal of Theoretical and Applied Finance* **5**(8):797–821.
- Papalexopoulos A, Hao S, Peng T-M. 1994. An implementation of a neural network based load forecasting model for the EMS. *IEEE Transactions on Power Systems* **9**(4):1956–1962.
- Philipson L, Willis H. 1998. *Understanding Electric Utilities and Deregulation*. Marcel Dekker, Inc: New York; 1–24.
- Santos P, Martins A, Pires A. 2003. On the use of reactive power as an endogenous variable in short-term load forecasting. *IJER International Journal of Energy Research* **27**(5):513–529.
- Sargunaraj S, Gupta D, Devi S. 1997. Short-term load forecasting for demand side management. *IEE Proceedings—Generation Transmission and Distribution* **144**(1):68–74.
- Senjyu T, Takara H, Uezato K, Funabashi T. 2002. One-hour-ahead load forecasting using neural network. *IEEE Transactions on Power Systems* **17**(1):113–118.